



DATE: August 22, 2017

FROM: Crystal Steele, PG, REHP  
Environmental Manager

RE: Morrison Springs Sample Results – Advisory Still in Effect

Water samples collected at Morrison Springs on August 21, 2017 are still above the public health threshold for fecal indicator bacteria. Water quality exceedances are based upon the US Environmental Protection Agency's (EPA) recommended standard of no more than 61 Enterococci CFU/100mL in any single sample. Sample results were 72 and 92 Enterococci CFU/100mL. We will be resampling again next week.